Heather Shirley Smith
Deputy General Counsel

Duke Energy
40 W. Broad Street
Suite 690
Greenville, SC 29601

o: 864.370.5045
f: 864.370.5183
heather.smith@duke-energy.com

March 1, 2019

VIA ELECTRONIC FILING

The Honorable Jocelyn G. Boyd
Chief Clerk/Administrator
The Public Service Commission of South Carolina
101 Executive Center Drive, Suite 100
Columbia SC 29210

Re: Duke Energy Progress, LLC – 2018 Meter Testing Results
Docket No. 1989-499-E

Dear Mrs. Boyd:

Enclosed for filing please find Duke Energy Progress LLC's 2018 Final Sample and Periodic Histograms and All Group Summary Program Table as approved in Docket 1989-499-E, Order No. 90-131. The results represent combined North Carolina and South Carolina figures. In addition, a copy of the results is being submitted to the South Carolina Office of Regulatory Staff pursuant to 10 S.C. Code Ann. Reg 103-370(1).

Please do not hesitate to contact me if you have any questions or require any further information.

Sincerely,

Heather Shirley Smith

Heather Shirley Smith

Enclosure

cc: Sarah Johnson, Office of Regulatory Staff (via email w/enc.)
Andrew Bateman, Office of Regulatory Staff (via email w/enc.)
Marcus Preston (via email w/enc.)

Duke Energy Progress
2018 Watthour Meter Periodics
Watthour Meter Groupings

Meters in periodic groups were not tested in 2018 as they were all tested within the 16 year interval required.

Duke Energy Progress
2018 Watthour Meter Samples
Watthour Meter Groupings

Group	Mfg.	Type(s)	Description	Test Plan	Sample Size	Population	Sample Conclusion
11	Elster	A1+	Single Phase, self-contained, demand and TOU	Double Sample Phase-I	166	1,363	Pass
12	Elster	A3	Single Phase, self-contained, demand and TOU	Double Sample Phase-I	166	5,576	Pass
16	Landis & Gyr	Focus AL	Single Phase, self-contained, with ERT Module	Double Sample Phase-I	167	3,124	Pass
20	Itron	Centron	Single-phase, self-contained, with ERT Module	Double Sample Phase-I	165	3,580	Pass
21	Itron	Centron	Single-phase, self-contained, with ERT Module	Double Sample Phase-I	167	298,672	Pass
23	Itron	Centron	Single-phase, self-contained, with ERT Module	Double Sample Phase-I	177	234,983	Pass
24	Itron	Centron	Single-phase, self-contained, with ERT Module	Double Sample Phase-I	166	225,591	Pass
25	Itron	Centron	Single-phase, self-contained, with ERT Module	Double Sample Phase-I	172	351,551	Pass
27	Itron	Centron	Single-phase, self-contained, with ERT Module	Double Sample Phase-I	168	250,704	Pass
30	General Electric	EV, I70,KV, KV2	Single Phase, self-contained, demand and TOU	Double Sample Phase-I	313	514	Pass
35	ABB/ Elster	A1	Single Phase self-contained, demand and TOU	Double Sample Phase-I	181	1,258	Pass
36	General Electric	I210	Single-phase, self-contained, with ERT Module	Double Sample Phase-I	169	9,882	Pass

43	Landis & Gyr	Focus AXR	Three-phase self-contained, demand and TOU	Double Sample Phase-I	167	4,643	Pass
44	Landis & Gyr	Focus AXR	Single-phase self-contained, demand and TOU	Double Sample Phase-I	174	23,948	Pass
46	Itron	Centron, Sentinel	Three-phase and network, self-contained with ERT Module	Double Sample Phase-I	171	44,231	Pass
47	Itron	Centron, Sentinel	Three-phase and network, self-contained with ERT Module	Double Sample Phase-I	169	10,749	Pass
51	Elster	A3	Three-phase and network, self-contained, demand and TOU	Double Sample Phase I	169	1,046	Pass
65	Elster	A3	Single-phase, self-contained, demand and TOU	Double Sample Phase I	180	2,500	Pass

Duke Energy Progress
Meter Classification Key

A break-down of the code used for the DEP meter classifications ** ** ** (12 34 56).

For example: SS *1 NI, would be a Solid-State meter either self contained or T-rated Non-initiating

For positions 12
ND = Non-Demand
TD = Thermal Demand
MD = Mechanical Demand
ED = Electronic Demand (hybrid)
TO = Time-of-use
TR = Transducer
SS = Solid-State meter
RE = Recorder
VV = Volt-Squared Hour
SD = Solid-State Demand
ST = Solid-State TOU
SP = Solid-State Prepay

For positions 34
S = Self contained
T = Transformer Rated
1 = Single Phase
3 = Three Phase

For Positions 56
NI = Non-Initiating
WI=With-Initiating

Duke Energy Progress

2018 SELECTIVE SAMPLE

Watthour Meter Group S-011 Summary

Group Information

Manufacturer: ELSTER/ABB/WESTINGHOUSE

Watthour Meter Type(s): A1+

PE Type Code(s): H38,H39,H40

Meter Classification: S*S1NI

Methodology: Double Sampling Ph 1

Population: 1363

Sample Size: 185

Weighted Average Test Summary

Mean: 99.886

Standard Deviation: 0.0596

Number of Test > 102%: 0

Number of Test 98 - 102%: 166

Number of Test < 98%: 0

Group Test Summary

This Group PASSES the Sample test since the number of fast watthour meters is less than 2

Histogram of Group S-011 Meter Accuracies



Duke Energy Progress

2018 SELECTIVE SAMPLE

Watthour Meter Group S-012 Summary

Group Information

Manufacturer: ELSTER/ABB/WESTINGHOUSE

Watthour Meter Type(s): A3

PE Type Code(s): H43,H44,H52,H53,H62

Meter Classification: S*S1NI

Methodology: Double Sampling Ph 1

Population: 5476

Sample Size: 185

Weighted Average Test Summary

Mean: 99.928

Standard Deviation: 0.0734

Number of Test > 102%: 0

Number of Test 98 - 102%: 165

Number of Test < 98%: 0

Group Test Summary

This Group PASSES the Sample test since the number of fast watthour meters is less than 2

Histogram of Group S-012 Meter Accuracies



Duke Energy Progress

2018 SELECTIVE SAMPLE

Watthour Meter Group S-016 Summary

Group Information

Manufacturer: LANDIS & GYR/DUNCAN

Watthour Meter Type(s): FOCUS AL

PE Type Code(s): D21

Meter Classification: SSS1NI

Methodology: Double Sampling Ph 1

Population: 3124

Sample Size: 185

Weighted Average Test Summary

Mean: 99.966

Standard Deviation: 0.0462

Number of Test > 102%: 0

Number of Test 98 - 102%: 167

Number of Test < 98%: 0

Group Test Summary

This Group PASSES the Sample test since the number of fast watthour meters is less than 2

Histogram of Group S-016 Meter Accuracies



Duke Energy Progress

2018 SELECTIVE SAMPLE

Watthour Meter Group S-020 Summary

Group Information

Manufacturer: ITRON

Watthour Meter Type(s): CENTRON

PE Type Code(s): S24

Meter Classification: SSS1NI

Methodology: Double Sampling Ph 1

Population: 3580

Sample Size: 185

Weighted Average Test Summary

Mean: 99.836

Standard Deviation: 0.1409

Number of Test > 102%: 0

Number of Test 98 - 102%: 165

Number of Test < 98%: 0

Group Test Summary

This Group PASSES the Sample test since the number of fast watthour meters is less than 2

Histogram of Group S-020 Meter Accuracies



Duke Energy Progress

2018 SELECTIVE SAMPLE

Watthour Meter Group S-021 Summary

Group Information

Manufacturer: ITRON

Watthour Meter Type(s): C1SR

PE Type Code(s): S25

Meter Classification: SSS1NI MMR

Methodology: Double Sampling Ph 1

Population: 298672

Sample Size: 185

Weighted Average Test Summary

Mean: 99.961

Standard Deviation: 0.1171

Number of Test > 102%: 0

Number of Test 98 - 102%: 165

Number of Test < 98%: 0

Group Test Summary

This Group PASSES the Sample test since the number of fast watthour meters is less than 2

Histogram of Group S-021 Meter Accuracies



Duke Energy Progress

2018 SELECTIVE SAMPLE

Watthour Meter Group S-023 Summary

Group Information

Manufacturer: ITRON

Watthour Meter Type(s): C1SR

PE Type Code(s): S27

Meter Classification: SSS1NI MMR

Methodology: Double Sampling Ph 1

Population: 234983

Sample Size: 185

Weighted Average Test Summary

Mean: 99.923

Standard Deviation: 0.1093

Number of Test > 102%: 0

Number of Test 98 - 102%: 176

Number of Test < 98%: 0

Group Test Summary

This Group PASSES the Sample test since the number of fast watthour meters is less than 2

Histogram of Group S-023 Meter Accuracies



Duke Energy Progress

2018 SELECTIVE SAMPLE

Watthour Meter Group S-024 Summary

Group Information

Manufacturer: ITRON

Watthour Meter Type(s): C1SR

PE Type Code(s): S26,S28

Meter Classification: SSS1NI MMR

Methodology: Double Sampling Ph 1

Population: 255951

Sample Size: 185

Weighted Average Test Summary

Mean: 99.952

Standard Deviation: 0.1304

Number of Test > 102%: 0

Number of Test 98 - 102%: 165

Number of Test < 98%: 0

Group Test Summary

This Group PASSES the Sample test since the number of fast watthour meters is less than 2

Histogram of Group S-024 Meter Accuracies



Duke Energy Progress

2018 SELECTIVE SAMPLE

Watthour Meter Group S-025 Summary

Group Information

Manufacturer: ITRON

Watthour Meter Type(s): CENTRON (C1SR)

PE Type Code(s): S29,S30

Meter Classification: SSS1NI MMR

Methodology: Double Sampling Ph 1

Population: 351551

Sample Size: 185

Weighted Average Test Summary

Mean: 99.912

Standard Deviation: 0.1257

Number of Test > 102%: 0

Number of Test 98 - 102%: 172

Number of Test < 98%: 0

Group Test Summary

This Group PASSES the Sample test since the number of fast watthour meters is less than 2

Histogram of Group S-025 Meter Accuracies



Duke Energy Progress

2018 SELECTIVE SAMPLE

Watthour Meter Group S-027 Summary

Group Information

Manufacturer: ITRON

Watthour Meter Type(s): CENTRON (C1SR)

PE Type Code(s): S31

Meter Classification: SSS1NI

Methodology: Double Sampling Ph 1

Population: 250704

Sample Size: 185

Weighted Average Test Summary

Mean: 99.968

Standard Deviation: 0.0844

Number of Test > 102%: 0

Number of Test 98 - 102%: 167

Number of Test < 98%: 0

Group Test Summary

This Group PASSES the Sample test since the number of fast watthour meters is less than 2

Histogram of Group S-027 Meter Accuracies



Duke Energy Progress

2018 SELECTIVE SAMPLE

Watthour Meter Group S-030 Summary

Group Information

Manufacturer: GENERAL ELECTRIC

Watthour Meter Type(s): EV,KV,KV2,I70

PE Type Code(s): E42,E43,E44,E45,E46,E47,E48,E49,E50,E51,E52,E53

Meter Classification: S*S1NI

Methodology: Double Sampling Ph 1

Population: 313

Sample Size: 186

Weighted Average Test Summary

Mean: 99.821

Standard Deviation: 0.1787

Number of Test > 102%: 0

Number of Test 98 - 102%: 177

Number of Test < 98%: 1

Group Test Summary

This Group PASSES the Sample test since the number of fast watthour meters is less than 2

Histogram of Group S-030 Meter Accuracies



Duke Energy Progress

2018 SELECTIVE SAMPLE

Watthour Meter Group S-035 Summary

Group Information

Manufacturer: ELSTER/ABB/WESTINGHOUSE

Watthour Meter Type(s): A1

PE Type Code(s): H21,H22,H23,H24,H25,H30,H31,H32,H33,H34,H35,H36,H37

Meter Classification: S*S1*I

Methodology: Double Sampling Ph 1

Population: 1258

Sample Size: 184

Weighted Average Test Summary

Mean: 99.969

Standard Deviation: 0.1077

Number of Test > 102%: 0

Number of Test 98 - 102%: 181

Number of Test < 98%: 0

Group Test Summary

This Group PASSES the Sample test since the number of fast watthour meters is less than 2

Histogram of Group S-035 Meter Accuracies



Duke Energy Progress

2018 SELECTIVE SAMPLE

Watthour Meter Group S-036 Summary

Group Information

Manufacturer: GENERAL ELECTRIC

Watthour Meter Type(s): I-210

PE Type Code(s): G42

Meter Classification: SSS1NI

Methodology: Double Sampling Ph 1

Population: 9882

Sample Size: 185

Weighted Average Test Summary

Mean: 99.952

Standard Deviation: 0.1274

Number of Test > 102%: 0

Number of Test 98 - 102%: 165

Number of Test < 98%: 0

Group Test Summary

This Group PASSES the Sample test since the number of fast watthour meters is less than 2

Histogram of Group S-036 Meter Accuracies



Duke Energy Progress

2018 SELECTIVE SAMPLE

Watthour Meter Group S-043 Summary

Group Information

Manufacturer: LANDIS & GYR/DUNCAN

Watthour Meter Type(s): FOCUS AXR

PE Type Code(s): C24

Meter Classification: STS3NI

Methodology: Double Sampling Ph 1

Population: 4643

Sample Size: 185

Weighted Average Test Summary

Mean: 99.987

Standard Deviation: 0.0463

Number of Test > 102%: 0

Number of Test 98 - 102%: 165

Number of Test < 98%: 0

Group Test Summary

This Group PASSES the Sample test since the number of fast watthour meters is less than 2

Histogram of Group S-043 Meter Accuracies



Duke Energy Progress

2018 SELECTIVE SAMPLE

Watthour Meter Group S-044 Summary

Group Information

Manufacturer: LANDIS & GYR/DUNCAN

Watthour Meter Type(s): FOCUS AXR

PE Type Code(s): U19

Meter Classification: STS1NI

Methodology: Double Sampling Ph 1

Population: 23948

Sample Size: 185

Weighted Average Test Summary

Mean: 99.972

Standard Deviation: 0.048

Number of Test > 102%: 0

Number of Test 98 - 102%: 174

Number of Test < 98%: 0

Group Test Summary

This Group PASSES the Sample test since the number of fast watthour meters is less than 2

Histogram of Group S-044 Meter Accuracies



Duke Energy Progress

2018 SELECTIVE SAMPLE

Watthour Meter Group S-046 Summary

Group Information

Manufacturer: ITRON

Watthour Meter Type(s): CENTRON

PE Type Code(s): N16,N18,N19

Meter Classification: SSS*NI

Methodology: Double Sampling Ph 1

Population: 44231

Sample Size: 186

Weighted Average Test Summary

Mean: 99.935

Standard Deviation: 0.4463

Number of Test > 102%: 0

Number of Test 98 - 102%: 170

Number of Test < 98%: 1

Group Test Summary

This Group PASSES the Sample test since the number of fast watthour meters is less than 2

Histogram of Group S-046 Meter Accuracies



Duke Energy Progress

2018 SELECTIVE SAMPLE

Watthour Meter Group S-047 Summary

Group Information

Manufacturer: ITRON

Watthour Meter Type(s): SENTINEL

PE Type Code(s): N17

Meter Classification: SSS3NI

Methodology: Double Sampling Ph 1

Population: 10749

Sample Size: 185

Weighted Average Test Summary

Mean: 100.026

Standard Deviation: 0.0969

Number of Test > 102%: 0

Number of Test 98 - 102%: 165

Number of Test < 98%: 0

Group Test Summary

This Group PASSES the Sample test since the number of fast watthour meters is less than 2

Histogram of Group S-047 Meter Accuracies



Duke Energy Progress

2018 SELECTIVE SAMPLE

Watthour Meter Group S-051 Summary

Group Information

Manufacturer: ELSTER/ABB/WESTINGHOUSE

Watthour Meter Type(s): A3

PE Type Code(s): Y72,Y73,Y74,Y75,Y76,Y77,Y78,Y79,Y80,Y81,Y82,Y83,Y84,Y85,Y86,Y87,Y88,Y89

Meter Classification: S*S**I

Methodology: Double Sampling Ph 1

Population: 1046

Sample Size: 186

Weighted Average Test Summary

Mean: 99.967

Standard Deviation: 0.0459

Number of Test > 102%: 0

Number of Test 98 - 102%: 169

Number of Test < 98%: 0

Group Test Summary

This Group PASSES the Sample test since the number of fast watthour meters is less than 2

Histogram of Group S-051 Meter Accuracies



Duke Energy Progress

2018 SELECTIVE SAMPLE

Watthour Meter Group S-065 Summary

Group Information

Manufacturer: ELSTER/ABB/WESTINGHOUSE

Watthour Meter Type(s): A3

PE Type Code(s): H42,H45,H46,H47,H48,H49,H50,H51,H54,H55,H56,H57,H58,H59,H60,H61

Meter Classification: STS1*I

Methodology: Double Sampling Ph 1

Population: 2500

Sample Size: 184

Weighted Average Test Summary

Mean: 100

Standard Deviation: 0.032

Number of Test > 102%: 0

Number of Test 98 - 102%: 180

Number of Test < 98%: 0

Group Test Summary

This Group PASSES the Sample test since the number of fast watthour meters is less than 2

Histogram of Group S-065 Meter Accuracies